

**Wharton Borough**  
**BUREAU OF FIRE PREVENTION**  
**10 Robert St.**  
**Wharton, NJ 07885**  
**MAIN: 973-361-8444 / FAX: 973-361-5281**

**PERMIT APPLICATION –Storage or retail sale of sparkling devices and novelties in any temporary or permanent structure, when the pyrotechnic content exceeds 125 pounds; as defined in Section 202, and shall comply with Section 5609, and NFPA 1124.**

Date of Application: \_\_\_\_\_ Permit Type: (2) 5:70-2.7(a)4vii Fee: \$214.00

Applicant: Name: \_\_\_\_\_

Address: \_\_\_\_\_

\_\_\_\_\_

Phone: \_\_\_\_\_

Location: Storage: \_\_\_\_\_

\_\_\_\_\_

Retail: \_\_\_\_\_

\_\_\_\_\_

Contact Person: \_\_\_\_\_ Phone: \_\_\_\_\_

Emergency Contact: \_\_\_\_\_ Phone: \_\_\_\_\_

**The following conditions shall be in compliance at all time the products are on premises:**

1. There shall be no fewer than two (2) portable fire extinguishers with a minimum rating of 2A, at least one of which shall be of the pressurized water type. The second extinguisher shall be of the multipurpose dry chemical type.
2. The location of the storage shall be defined by a drawing of the facility and marked appropriately.
3. All aisles in the retail sales area shall be a minimum of forty eight inches at all times the facility is occupied by the public.
4. Merchandise on display or located on shelves or counters or other fixtures shall not be displayed to a height greater than six feet (6 ft.) above the floor surface.
5. Consumer novelties devices that are damaged shall be removed and not offered for sale.
6. Locations subject to spot inspection at any time
7. The storage and mercantile facility shall follow NJ IFC Section 5609 & NFPA 1124

**I hereby acknowledge that I have read this application and that the information given is correct, and that I am the owner, or duly authorized to act in the owner's behalf, and as such agree to comply with all applicable requirements of the N.J. Uniform Fire Code.**

Signature: \_\_\_\_\_

Title: \_\_\_\_\_