

R-112-22

RESOLUTION

WHEREAS, the Borough of Wharton has received a request dated August 25, 2022 from Wharton Woods, LLC, as concerns the Aspire at Morris Woods project at Block 1603, Lot 14, to allow for the substitution of C-900 polyvinyl chloride (PVC) pressure pipe for the ductile iron pipe required by Chapter 330, Section 17 of the Borough Ordinances, relevant to the construction of the watermain at this project, said request stemming from supply chain issues in obtaining ductile iron pipe; and

WHEREAS, the Borough Water and Sewer Engineer has advised that it has no objection to said substitution, by way of a Memorandum dated August 31, 2022.

NOW, THEREFORE, BE IT RESOLVED by the Mayor and Council that the request to utilize C-900 polyvinyl chloride (PVC) pressure pipe for the construction of the watermain at the Aspire at Morris Woods project at Block 1603, Lot 14 is hereby approved.

Adopted: September 12, 2022

BOROUGH OF WHARTON

ATTEST:

**_____
WILLIAM J. CHEGWIDDEN,
MAYOR**

**_____
Gabrielle Evangelista,
Borough Clerk**